

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7150-0026:175 Page 1 of 1

CATEGORY: Pull Station/Boxes

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 *Fax (978) 731-8881

DESIGN: Models 2099-9101, -9102, -9103, -9104, -9105, -9107, -9108, *-9147, *-9148, *-9149, *-9152, -9135, -9754, -9755, -9756, -9757, -9758, -9759, -9760, -9761, -9762, -9792, -9793, -9794, -9795, -9796 and -9797 boxes. Noncoded, addressable or pre-signal option. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as pull station for use with separately listed compatible control units. Addressable models are intended for use with Models 2120 (CSFM Listing No. 7170-0026:125 or 7165-0026:126) or Model 4100 (CSFM Listing No. 7165-0026:160 or 7170-0026:187) or *Model 4100U (CSFM Listing No. 7170-0026:250 and 7165-0026:251) or *Model 4004 (CSFM Listing No. 7165-0026:314) or Model 4020 (CSFM Listing No. 7165-0026:178) control units.

*Rev. 12-22-2002 JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 8, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**